

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	site description	Outlet type	Action Taken
ALBANY 1	1/11/2024 05:21	1/18/2024 12:28	70284328001	Lead	<1.0	5	ug/L			
ALBANY 3	1/11/2024 05:22	1/18/2024 12:30	70284328010	Lead	<1.0	5	ug/L			
ALBANY 4	1/11/2024 05:23	1/18/2024 12:31	70284328011	Lead	<1.0	5	ug/L			
ALBANY 6	1/11/2024 05:24	1/18/2024 12:33	70284328012	Lead	<1.0	5	ug/L			
ALBANY 7	1/11/2024 05:25	1/18/2024 12:34	70284328013	Lead	<1.0	5	ug/L			
ALBANY 9	1/11/2024 05:26	1/18/2024 12:36	70284328014	Lead	<1.0	5	ug/L			
ALBANY 10	1/11/2024 05:27	1/18/2024 12:38	70284328015	Lead	<1.0	5	ug/L			
ALBANY 12	1/11/2024 05:28	1/18/2024 12:39	70284328016	Lead	4.3	5	ug/L			
ALBANY 13	1/11/2024 05:29	1/18/2024 12:44	70284328017	Lead	<1.0	5	ug/L			
ALBANY 14 TEACHERS LOUNGE	1/11/2024 05:30	1/18/2024 12:45	70284328018	Lead	<1.0	5	ug/L			
ALBANY 16	1/11/2024 05:49	1/18/2024 12:47	70284328019	Lead	<1.0	5	ug/L			
ALBANY 17	1/11/2024 05:50	1/18/2024 12:48	70284328020	Lead	2.1	5	ug/L			
ALBANY 18	1/11/2024 05:53	1/18/2024 12:50	70284328021	Lead	2.8	5	ug/L			
ALBANY 19	1/11/2024 05:54	1/18/2024 12:54	70284328022	Lead	2.9	5	ug/L			
ALBANY 20	1/11/2024 05:51	1/18/2024 13:02	70284328023	Lead	1.6	5	ug/L			
ALBANY 21	1/11/2024 05:48	1/18/2024 13:06	70284328024	Lead	1.2	5	ug/L			
ALBANY 22	1/11/2024 05:45	1/18/2024 13:08	70284328025	Lead	<1.0	5	ug/L			
ALBANY 23 RM 203	1/11/2024 05:47	1/18/2024 13:10	70284328026	Lead	1.4	5	ug/L			
ALBANY 24	1/11/2024 06:32	1/18/2024 13:11	70284328027	Lead	<1.0	5	ug/L			
ALBANY 29 DF	1/11/2024 06:06	1/18/2024 13:13	70284328028	Lead	<1.0	5	ug/L			
ALBANY 30	1/11/2024 05:56	1/18/2024 13:14	70284328029	Lead	3.4	5	ug/L			
ALBANY 31	1/11/2024 06:00	1/18/2024 13:16	70284328030	Lead	19.3	5	ug/L	Rm 211	classroom sink	Posted Sign
ALBANY 32	1/11/2024 06:01	1/18/2024 13:20	70284328031	Lead	<1.0	5	ug/L			
ALBANY 33	1/11/2024 06:05	1/18/2024 13:23	70284328032	Lead	11.8	5	ug/L	Rm 213	classroom sink	Posted Sign
ALBANY 40	1/11/2024 06:02	1/18/2024 13:25	70284328033	Lead	5.5	5	ug/L	Rm 214	classroom sink	Posted Sign
ALBANY 41	1/11/2024 06:03	1/18/2024 13:28	70284328034	Lead	14.0	5	ug/L	Rm 215	classroom sink	Posted Sign
ALBANY 42	1/11/2024 05:57	1/18/2024 13:33	70284328035	Lead	8.6	5	ug/L	Rm 216	classroom sink	Posted Sign
ALBANY 47 DF ACROSS FROM 110	1/11/2024 05:36	1/18/2024 13:43	70284328036	Lead	<1.0	5	ug/L			
ALBANY 52	1/11/2024 05:38	1/18/2024 13:57	70284328037	Lead	1.5	5	ug/L			
ALBANY 53	1/11/2024 05:39	1/18/2024 14:00	70284328038	Lead	1.0	5	ug/L			
ALBANY 54	1/11/2024 05:40	1/18/2024 14:02	70284328039	Lead	3.7	5	ug/L			
ALBANY 55	1/11/2024 05:41	1/18/2024 14:03	70284328040	Lead	1.0	5	ug/L			
ALBANY 60	1/11/2024 06:18	1/18/2024 14:05	70284328041	Lead	<1.0	5	ug/L			
ALBANY 61	1/11/2024 06:20	1/18/2024 14:06	70284328042	Lead	<1.0	5	ug/L			
ALBANY 62	1/11/2024 06:21	1/18/2024 14:08	70284328043	Lead	8.7	5	ug/L	Rm 303	classroom sink	Posted Sign
ALBANY 63	1/11/2024 06:27	1/18/2024 14:10	70284328044	Lead	7.2	5	ug/L	Rm 304	classroom sink	Posted Sign
ALBANY 64	1/11/2024 06:28	1/18/2024 14:11	70284328045	Lead	<1.0	5	ug/L			Posted Sign
ALBANY 70	1/11/2024 06:24	1/18/2024 14:16	70284328046	Lead	7.1	5	ug/L	Rm 305	classroom sink	Posted Sign
ALBANY 71	1/11/2024 06:25	1/18/2024 14:17	70284328047	Lead	7.6	5	ug/L	RM 306	classroom sink	Posted Sign
ALBANY 72	1/11/2024 06:19	1/18/2024 14:19	70284328048	Lead	19.2	5	ug/L	Rm 307	classroom sink	Posted Sign
ALBANY 73	1/11/2024 06:12	1/18/2024 14:20	70284328049	Lead	1.4	5	ug/L			
ALBANY 74 A	1/11/2024 06:13	1/18/2024 14:22	70284328050	Lead	<1.0	5	ug/L			
ALBANY 74 B	1/11/2024 06:14	1/18/2024 14:24	70284328051	Lead	<1.0	5	ug/L			
ALBANY 77	1/11/2024 06:15	1/18/2024 14:25	70284328052	Lead	<1.0	5	ug/L			

NYSDOH Action Level for Lead In Schools of 5 ppb