

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	
MLK 2	1/10/2024 07:10	1/18/2024 18:25	70284331001	Lead	1.1	5	ug/L	
MLK 8	1/10/2024 06:57	1/18/2024 18:26	70284331002	Lead	<1.0	5	ug/L	
MLK 9 DF CAFETERIA	1/10/2024 06:58	1/18/2024 18:28	70284331003	Lead	<1.0	5	ug/L	
MLK 11	1/10/2024 06:59	1/18/2024 18:29	70284331004	Lead	<1.0	5	ug/L	
MLK 12	1/10/2024 07:00	1/18/2024 18:34	70284331005	Lead	<1.0	5	ug/L	
MLK 13	1/10/2024 07:01	1/18/2024 18:35	70284331006	Lead	2.7	5	ug/L	
MLK 14	1/10/2024 07:02	1/18/2024 18:37	70284331007	Lead	3.4	5	ug/L	
MLK 18 A	1/10/2024 07:04	1/18/2024 18:39	70284331008	Lead	<1.0	5	ug/L	
MLK 18 B	1/10/2024 07:09	1/18/2024 18:40	70284331009	Lead	<1.0	5	ug/L	
MLK 19	1/10/2024 07:05	1/18/2024 18:42	70284331010	Lead	<1.0	5	ug/L	
MLK 20	1/10/2024 07:06	1/18/2024 18:43	70284331011	Lead	1.7	5	ug/L	
MLK 28	1/10/2024 07:13	1/18/2024 18:45	70284331012	Lead	<1.0	5	ug/L	
MLK 29	1/10/2024 07:14	1/18/2024 18:46	70284331013	Lead	<1.0	5	ug/L	
MLK 30	1/10/2024 07:15	1/18/2024 18:48	70284331014	Lead	<1.0	5	ug/L	
MLK 31	1/10/2024 07:16	1/19/2024 10:09	70284331015	Lead	<1.0	5	ug/L	
MLK 32	1/10/2024 07:17	1/19/2024 10:15	70284331016	Lead	1.6	5	ug/L	
MLK 33	1/10/2024 07:18	1/19/2024 10:20	70284331017	Lead	2.5	5	ug/L	
MLK 34	1/10/2024 07:20	1/19/2024 10:24	70284331018	Lead	3.1	5	ug/L	
MLK 35	1/10/2024 07:21	1/19/2024 10:25	70284331019	Lead	2.1	5	ug/L	
MLK 36	1/10/2024 07:22	1/19/2024 10:27	70284331020	Lead	1.2	5	ug/L	
MLK 37	1/10/2024 07:23	1/19/2024 10:29	70284331021	Lead	1.3	5	ug/L	
MLK 38	1/10/2024 07:24	1/19/2024 10:30	70284331022	Lead	<1.0	5	ug/L	
MLK 39	1/10/2024 07:25	1/19/2024 10:32	70284331023	Lead	<1.0	5	ug/L	
MLK 40	1/10/2024 07:26	1/19/2024 10:33	70284331024	Lead	<1.0	5	ug/L	
MLK 41	1/10/2024 07:27	1/19/2024 10:35	70284331025	Lead	<1.0	5	ug/L	
MLK 42	1/10/2024 07:28	1/19/2024 10:36	70284331026	Lead	<1.0	5	ug/L	
MLK 43	1/10/2024 07:29	1/19/2024 10:38	70284331027	Lead	<1.0	5	ug/L	
MLK 45	1/10/2024 07:12	1/19/2024 10:42	70284331028	Lead	<1.0	5	ug/L	
MLK 51	1/10/2024 07:38	1/19/2024 10:44	70284331029	Lead	<1.0	5	ug/L	
MLK 52	1/10/2024 07:34	1/19/2024 10:45	70284331030	Lead	5.1	5	ug/L	Room 216 Sink 1 Posted Sign
MLK 53	1/10/2024 07:35	1/19/2024 10:47	70284331031	Lead	4.6	5	ug/L	
MLK 54	1/10/2024 07:36	1/19/2024 10:48	70284331032	Lead	6.3	5	ug/L	Room 216 Sink 3 Posted Sign
MLK 55	1/10/2024 07:33	1/19/2024 10:50	70284331033	Lead	<1.0	5	ug/L	

NYSDOH Action Level for Lead In Schools of 5 ppb